

**VFXT.EX3511
Hangers, Pipe**[Page Bottom](#)**Hangers, Pipe**[See General Information for Hangers, Pipe](#)**WARD MFG INC**115 GULICK ST
PO BOX 9
BLOSSBURG, PA 16912 USA

EX3511

Pipe hangers

Model	Hanger Type	Rod Size, in.	NPS*	Comments
3/8 Top-Beam C-Clamp	Universal beam clamp	3/8	Up to 4	—
1/2 Top-Beam C-Clamp	Top beam clamp	1/2	5 through 8	—
Wide Throat C-Clamp	Top beam clamp	3/8	Up to 4	—
Wide Throat C-Clamp	Top beam clamp	1/2	5 through 8	—
Regular C-Clamp	C-Clamp	3/8	Up to 4	—
Regular C-Clamp	C-Clamp	1/2	Up to 4	—

* NPS = Nominal pipe size

Trademark and/or Tradename: "JPW", "J.P. Ward", "W&K"

[Last Updated](#) on 2007-07-17[Questions?](#)[Notice of Disclaimer](#)[Page Top](#)

Copyright © 2008 Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2008 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

