



VIZQ.EX3507 Fittings, Union

Page Bottom

Fittings, Union

See General Information for Fittings, Union

WARD MFG INC

115 GULICK ST

PO BOX 9

BLOSSBURG, PA 16912 USA

EX3507

Model	Mtl	Type	Size In.	Marked Pressure	Rated Pressure (psig)
Fig. 1	MI	Union	1/4, 3/8, 1/2,	150	300
			3/4, 1, 1-1/4,		
			1-1/2, 2, 2-1/2, 3		
Fig. 4	MI	Union	1/4, 3/8, 1/2,	150	300
			3/4, 1, 1-1/4,		
			1-1/2, 2, 2-1/2, 3		
Fig. 10	MI	Union	1/4, 3/8, 1/2,	150	300
			3/4, 1, 1-1/4,		
			1-1/2, 2, 2-1/2, 3		
Fig. 2	MI	Union	1/4, 3/8, 1/2,	250	500
			3/4, 1, 1-1/4,		
			1-1/2, 2, 2-1/2, 3		
Fig. 11	MI	Union	1/4, 3/8, 1/2,	250	500
			3/4, 1, 1-1/4,		
			1-1/2, 2, 2-1/2, 3		
Fig. 3	MI	Union	1/4, 3/8, 1/2,	300	600
			3/4, 1, 1-1/4,		
			1-1/2, 2, 2-1/2, 3		
Fig. 9	MI	Union	1/4, 3/8, 1/2,	300	600
			3/4, 1, 1-1/4,		
			1-1/2, 2, 2-1/2, 3		
Fig. 12	MI	Union	1/4, 3/8, 1/2,	300	600
			3/4, 1, 1-1/4,		

1-1/2, 2, 2-1/2, 3

Trademark and/or Tradename: "JPW", "J.P. Ward", "W&K"

Last Updated on 1997-07-02

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2008 Underwriters Laboratories Inc.®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2008 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.





HYJV.EX3507 Unions

[Page Bottom](#)

Unions

[See General Information for Unions](#)

WARD MFG INC

115 GULICK ST
PO BOX 9
BLOSSBURG, PA 16912 USA

EX3507

Malleable iron unions, Fig. 1, 4 and 10 , for max pressures of 300 psi, sizes 1/4 to 3 in. incl.

Figs. 2 and 11 , for max pressures of 500 psi, sizes 1/4 to 3 in. incl.

Figs. 3, 9 and 12 , for max pressures of 600 psi, sizes 1/4 to 3 in. incl.

Trademark and/or Tradename: "JPW", "J.P. Ward", "W&K"

[Last Updated](#) on 1997-07-02

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2008 Underwriters Laboratories Inc.®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2008 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

